



JOHN ELIAS BALDACCI  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE  
04333-0016

DAVID A. COLE  
COMMISSIONER

November 22, 2004  
Subject: Statewide Rest Area  
Improvements  
Project No. STP-1124(200)X  
PIN 11242.00  
**Bid Amendment No. 2**

Dear Sir/Ms.:

The Department has received the following Requests for Information:

**Q)** I have been told by a vendor that there is a polyester waterless urinal, but if it needs to be ADA than it is ceramic. What does the State want?

**A)** *Waterless Co. Model 2004 Fiberglass reinforced polyester is ADA (ANSI Z 124.9) compliant per mfg.*

**Q)** A standard Steelcraft door is 18 gage with a 16 gage frame, to get a 16 gage door and a 14 gage frame it is considerably more money and a 6-8 week lead time. Is the door specified really what the state wants?

**A)** *The door and frame are as specified under Section 02540-Vault Toilet Tank and Accessories, Section 2.5, Door frame and hardware.*

**Q)** There is no allowance for ledge to be excavated. Is it incidental to the site locations or will the actual location be moved to get away from ledge if excavated?

**A)** *Yes, we will attempt to relocate if necessary to avoid ledge. No blasting anticipated.*

**Q)** There are no bid items for seeding and mulching that is required at the sites. Is this work incidental to each site item?

**A)** *Yes, seeding and mulching is incidental to each site and should be included.*

Consider this information prior to submitting your bid on December 1, 2004.

Sincerely,

Scott Bickford  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER